



epc brighton

Tel. 01273 321864

Mobile: 07718 319595

Email. johnhole@epcbrighton.com

**First and Second Floors
55 North Street, Portslade BN41 1DH**



Energy Performance Certificate



Energy performance certificate (EPC)

First and Second Floors
55 North Street
Portslade
BN41 1DH

Energy rating

F

Valid until: **14 September 2032**

Certificate number: **0988-0923-0718-0115-8752**

Property type

Offices and Workshop Businesses

Total floor area

1204 square metres

Rules on letting this property



You may not be able to let this property.


This property has an energy rating of F. The landlord cannot grant a tenancy to new or existing tenants, unless an exemption has been registered.

From 1 April 2023, landlords will not be allowed to continue letting a non-domestic property on an existing lease if that property has an energy rating of F or G.

Properties can be let if they have an energy rating from A+ to E. The [recommendation report](#) sets out changes you can make to improve the property's rating.

Energy efficiency rating for this property

This property's current energy rating is F.



Properties are given a rating from A+ (most efficient) to G (least efficient).

Properties are also given a score. The larger the number, the more carbon dioxide (CO₂) your property is likely to emit.

How this property compares to others

Properties similar to this one could have ratings:

If newly built



5 | A

If typical of the existing stock



21 | A

Breakdown of this property's energy performance

Main heating fuel

Grid Supplied Electricity

Building environment

Heating and Natural Ventilation

Assessment level

3

Building emission rate (kgCO₂/m² per year)

43.34

Primary energy use (kWh/m² per year)

456

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/9375-4372-7106-7557-2812\)](#).

Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

Assessor contact details

Assessor's name	John Hole
Telephone	01273 321864
Email	johnhole@epcbrighton.com

Accreditation scheme contact details

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor ID	EES/015102
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

Assessment details

Employer	EPC Brighton Ltd
Employer address	16 Holmes Avenue Brighton BN3 7LA
Assessor's declaration	The assessor is employed by the property owner.
Date of assessment	25 August 2022
Date of certificate	15 September 2022

Energy performance certificate (EPC) recommendation report

First and Second Floors
55 North Street
Portslade
BN41 1DH

Report number
9375-4372-7106-7557-2812

Valid until
14 September 2032

Energy rating and EPC

This property's current energy rating is F.

For more information on the property's energy performance, see the EPC for this property.

Recommendations

Make these changes to improve the property's energy efficiency.

Recommended improvements are grouped by the estimated time it would take for the change to pay for itself. The assessor may also make additional recommendations.

Each recommendation is marked as low, medium or high. This shows the potential impact of the change on reducing the property's carbon emissions.

Changes that pay for themselves within 3 years

Recommendation	Potential impact
Replace tungsten GLS lamps with CFLs: Payback period dependent on hours of use.	High
In some spaces, the solar gain limit defined in the NCM is exceeded, which might cause overheating. Consider solar control measures such as the application of reflective coating or shading devices to windows.	Medium

Changes that pay for themselves within 3 to 7 years

Recommendation	Potential impact
Add optimum start/stop to the heating system.	Low

Changes that pay for themselves in more than 7 years

Recommendation	Potential impact
Some walls have uninsulated cavities - introduce cavity wall insulation.	Medium
Some windows have high U-values - consider installing secondary glazing.	Medium
Add weather compensation controls to heating system.	Low
Add local time control to heating system.	Low
Some solid walls are poorly insulated - introduce or improve internal wall insulation.	Medium

Property and report details

Report issued on	15 September 2022
Total useful floor area	1204 square metres
Building environment	Heating and Natural Ventilation
Calculation tool	G-ISBEM Ltd, G-ISBEM, v25.0, SBEM, v6.1.b.0

Assessor's details

Assessor's name	John Hole
Telephone	01273 321864
Email	johnhole@epcbrighton.com
Employer's name	EPC Brighton Ltd
Employer's address	16 Holmes Avenue Brighton BN3 7LA
Assessor ID	EES/015102
Assessor's declaration	The assessor is employed by the property owner.
Accreditation scheme	Elmhurst Energy Systems Ltd