


Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's current energy rating is D.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

1 of 3 26/10/2023, 16:25

How this property compares to others

Properties similar to this one could have ratings:

If newly built	21 A
If typical of the existing stock	61 C

Breakdown of this property's energy performance

Main heating fuel	Natural Gas
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO2/m2 per year)	51.89
Primary energy use (kWh/m2 per year)	301

Recommendation report

Guidance on improving the energy performance of this property can be found in the recommendation report (/energy-certificate/2060-4619-9090-1206-5221).

2 of 3 26/10/2023, 16:25

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Damian Williamson
Telephone	0203 397 8220
Email	hello@propcert.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Email	info@quidos.co.uk	
Telephone	01225 667 570	
Assessor's ID	QUID206214	
Accreditation scheme	Quidos Limited	

About this assessment

Employer	PropCert
Employer address	Provident House, Burrell Row, Beckenham, BR3 1AT
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	25 January 2021
Date of certificate	26 January 2021

3 of 3 26/10/2023, 16:25