Energy performance certificate (EPC) Q4 Quorum Business Park Longbenton Newcastle NE12 8EZ Property type Offices and Workshop Businesses Total floor area 9769 square metres

Rules on letting this property


Properties can be let if they have an energy rating from A+ to E.

If a property has an energy rating of F or G, the landlord cannot grant a tenancy to new or existing tenants, unless an exemption has been registered.

From 1 April 2023, landlords will not be allowed to continue letting a non-domestic property on an existing lease if that property has an energy rating of F or G.

Energy efficiency rating for this property

This property's current energy rating is C.



Properties are given a rating from A+ (most efficient) to G (least efficient).

Properties are also given a score. The larger the number, the more carbon dioxide (CO2) your property is likely to emit.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

15 | A

If typical of the existing stock

60 | C

Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Air Conditioning
Assessment level	3
Building emission rate (kgCO2/m2 per year)	10.61
Primary energy use (kWh/m2 per year)	116

Recommendation report

Guidance on improving the energy performance of this property can be found in the <u>recommendation</u> <u>report (/energy-certificate/9554-0506-7530-7558-2326)</u>.

Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

Assessor contact details

Assessor's name Gregory Broadbent Telephone 07812125787

Email <u>g.broadbent@gesltd.uk</u>

Accreditation scheme contact details

Accreditation scheme Elmhurst Energy Systems Ltd

Assessor ID EES/022286
Telephone 01455 883 250

Email <u>enquiries@elmhurstenergy.co.uk</u>

Assessment details

Employer Godfreys Estate Services

Employer address 3 Snake Lane, Duffield, DE56 4FF

Assessor's declaration The assessor is not related to the owner of the

property.

Date of assessment 23 June 2022 Date of certificate 24 June 2022